



ANALYTICAL REPORT

PREPARED FOR

Attn: Verde Glen DWID
Verde Glen DWID
232 S. Conifer Dr.
Payson AZ 85541

Generated 3/28/2025 1:42 PM

JOB DESCRIPTION

Verde Glen DWID AZ0404040

JOB NUMBER

380-137562-1

Eurofins Eaton Analytical Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Eaton Analytical, LLC Project Manager.

Authorization



Generated
3/28/2025 1:42 PM

Authorized for release by
Thomas D French, Project Manager
Tom.French@et.eurofinsus.com

DRINKING WATER ANALYSIS REPORTING FORM

INORGANIC CHEMICAL (IOCs)

*** Entry Point to the Distribution System (EPDS) Only ***

*** PUBLIC WATER SYSTEM INFORMATION ***

>>> TO BE FILLED OUT BY SYSTEM PERSONNEL <<<<

AZ0404040

PWS ID Number

02/25/2025

Sample Date

08:00

Sample Time (24HR CLOCK)

water@verdeglendwid.com

Owner/Contact Email Address

Verde Glen DWID

PWS Name

Verde Glen DWID

Owner/Contact Person

480-888-5353

Owner/Contact Phone Number

SAMPLE TYPE

☒ Compliance Monitoring

SAMPLE COLLECTION POINT

☒ Entry Point to the Distribution System

EPDS 001

For MCL or Composite Level Sample Exceedance

Original Violation Specimen Number

SAMPLE TYPE

☐ Confirmation

- or -

☐ Confirmation Composite

*** INORGANIC CHEMICAL ANALYSIS ***

>>> TO BE COMPLETED BY LABORATORY PERSONNEL <<<

Analysis Method	MCL	Reporting Limit	Contaminant Name	Cont. Code	Analysis Run Date	Result	Exceeds MCL	Exceeds Trigger Limit
200.8	0.010	0.005	Arsenic	1005	02/27/25 15:04	0.001	<input type="checkbox"/>	
200.8	2	1	Barium	1010	02/27/25 15:04	0.064	<input type="checkbox"/>	
200.8	0.005	0.0025	Cadmium	1015	02/27/25 15:04	<0.0005	<input type="checkbox"/>	
200.8	0.1	0.05	Chromium	1020	02/27/25 15:04	<0.0009	<input type="checkbox"/>	
SM 4500 F C	4	0.5	Fluoride	1025	02/28/25 20:56	0.097	<input type="checkbox"/>	
200.8	0.002	0.001	Mercury	1035	02/27/25 15:04	<0.0002	<input type="checkbox"/>	
300.0	10	2.5	Nitrate (as N)	1040	02/26/25 15:44	0.068	<input type="checkbox"/>	<input type="checkbox"/> (5 mg/L)
	1	0.25	Nitrite (as N)	1041			<input type="checkbox"/>	<input type="checkbox"/> (0.5 mg/L)
200.8	0.05	0.025	Selenium	1045	02/27/25 15:04	<0.002	<input type="checkbox"/>	
200.8	0.006	0.003	Antimony	1074	02/27/25 15:04	<0.001	<input type="checkbox"/>	
200.8	0.004	0.002	Beryllium	1075	02/27/25 15:04	<0.0003	<input type="checkbox"/>	
4500 CN F	0.2	0.1	Cyanide	1024	03/05/25 12:11	<0.025	<input type="checkbox"/>	
200.8	No MCL	0.05	Nickel*	1036	02/27/25 15:04	<0.001	<input type="checkbox"/>	
200.8	0.002	0.001	Thallium	1085	02/27/25 15:04	<0.0003	<input type="checkbox"/>	
200.7	No MCL	10	Sodium*	1052	02/27/25 15:41	3.6	<input type="checkbox"/>	

*** LABORATORY INFORMATION ***

>>> TO BE COMPLETED BY LABORATORY PERSONNEL <<<

380-137562-1

Specimen Number

Comment MAP 2025;

Lab ID Number AZ0833

Lab Name Eurofins Eaton Analytical Pomona

Phone Number (626) 386-1100

Lab Contact, Printed Name Thomas French

Authorized Signature

PWS Notification Date

PWS Person Notified

All units must be reported in milligrams per liter (mg/L)
*Contaminants without MCL
DWAR 2IN: Revised 07/2019

Submit completed form to:

EMAIL: WQD_Compliance_Data@azdeq.gov

-or-

MAIL: ADEQ Water Quality Compliance Data Unit (MC 5415B-1),

For questions go to: azdeq.gov/DWComplianceAssistance

1110 W. Washington St., Phoenix, AZ 85007.