



ANALYTICAL REPORT

PREPARED FOR

Attn: Verde Glen DWID
Verde Glen DWID
232 S. Conifer Dr.
Payson AZ 85541

Generated 10/7/2025 12:40 PM

JOB DESCRIPTION

Verde Glen DWID AZ0404040

JOB NUMBER

380-174310-1

Eurofins Eaton Analytical Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Eaton Analytical, LLC Project Manager.

Authorization



Generated
10/7/2025 12:40 PM

Authorized for release by
Thomas D French, Project Manager
Tom.French@et.eurofinsus.com

DRINKING WATER ANALYSIS REPORTING FORM

VOLATILE ORGANIC CHEMICALS (VOC)

*** Entry Point to the Distribution System (EPDS) Only ***

*** PUBLIC WATER SYSTEM INFORMATION ***

>>> TO BE FILLED OUT BY SYSTEM PERSONNEL <<<<

AZ0404040

PWS ID Number

10/01/2025

Sample Date

water@verdeglendwid.com

Owner/Contact Email Address

SAMPLE TYPE

☒ Compliance Monitoring

SAMPLE COLLECTION POINT

☒ Entry Point to the Distribution System

EPDS 001

Verde Glen DWID

PWS Name

Verde Glen DWID

Owner/Contact Person

480-888-5353

Owner/Contact Phone Number

For MCL or Composite Level Sample Exceedance

Original Violation Specimen Number

SAMPLE TYPE

☐ Confirmation

- or -

☐ Confirmation Composite

*** VOLATILE ORGANIC CHEMICAL ANALYSIS ***

>>> TO BE COMPLETED BY LABORATORY PERSONNEL <<<

Analysis Method	MCL	Reporting Limit	Contaminant Name	Cont. Code	Analysis Run Date	Result	Exceeds MCL	Exceeds Reporting Limit
524.2	0.007	0.0005	1,1-Dichloroethylene	2977	10/03/25 00:20	<0.0005	☐	☐
524.2	0.2	0.0005	1,1,1-Trichloroethane	2981	10/03/25 00:20	<0.0005	☐	☐
524.2	0.005	0.0005	1,1,2-Trichloroethane	2985	10/03/25 00:20	<0.0005	☐	☐
524.2	0.005	0.0005	1,2-Dichloroethane	2980	10/03/25 00:20	<0.0005	☐	☐
524.2	0.005	0.0005	1,2-Dichloropropane	2983	10/03/25 00:20	<0.0005	☐	☐
524.2	0.005	0.0005	Benzene	2990	10/03/25 00:20	<0.0005	☐	☐
524.2	0.005	0.0005	Carbon Tetrachloride	2982	10/03/25 00:20	<0.0005	☐	☐
524.2	0.07	0.0005	cis-1,2-Dichloroethylene	2380	10/03/25 00:20	<0.0005	☐	☐
524.2	0.7	0.0005	Ethylbenzene	2992	10/03/25 00:20	<0.0005	☐	☐
524.2	0.1	0.0005	(mono)chlorobenzene	2989	10/03/25 00:20	<0.0005	☐	☐
524.2	0.6	0.0005	o-Dichlorobenzene	2968	10/03/25 00:20	<0.0005	☐	☐
524.2	0.075	0.0005	para-Dichlorobenzene	2969	10/03/25 00:20	<0.0005	☐	☐
524.2	0.1	0.0005	Styrene	2996	10/03/25 00:20	<0.0005	☐	☐
524.2	0.005	0.0005	Tetrachloroethylene	2987	10/03/25 00:20	<0.0005	☐	☐
524.2	1	0.0005	Toluene	2991	10/03/25 00:20	<0.0005	☐	☐

380-174310-1

Specimen Number

Comment MAP 2025;



DRINKING WATER ANALYSIS REPORTING FORM

VOLATILE ORGANIC CHEMICALS (VOC)

*** Entry Point to the Distribution System (EPDS) Only ***

AZ0404040

PWS ID Number

Verde Glen DWID

PWS Name

SAMPLE COLLECTION POINT

☒ Entry Point to the Distribution System EPDS 001

SAMPLE SITE ID EPDS001

*** VOLATILE ORGANIC CHEMICAL ANALYSIS ***

>>> TO BE COMPLETED BY LABORATORY PERSONNEL <<<

Analysis Method	MCL	Reporting Limit	Contaminant Name	Cont. Code	Analysis Run Date	Result	Exceeds MCL	Exceeds Reporting Limit
524.2	0.1	0.0005	Trans-1,2-Dichloroethylene	2979	10/03/25 00:20	<0.0005	☐	☐
524.2	0.005	0.0005	Trichloroethylene	2984	10/03/25 00:20	<0.0005	☐	☐
524.2	0.002	0.0005	Vinyl Chloride	2976	10/03/25 00:20	<0.0003	☐	☐
524.2	10	0.0015	Xylenes, Total	2955	10/03/25 00:20	<0.0005	☐	☐
524.2	0.07	0.0005	1,2,4-Trichlorobenzene	2378	10/03/25 00:20	<0.0005	☐	☐
524.2	0.005	0.0005	Dichloromethane	2964	10/03/25 00:20	<0.0005	☐	☐

*** LABORATORY INFORMATION ***

>>> TO BE COMPLETED BY LABORATORY PERSONNEL <<<

380-174310-1

Specimen Number

Comment MAP 2025;

Lab ID Number AZ0833

Lab Name Eurofins Eaton Analytical Pomona

Phone Number (626) 386-1100

Lab Contact, Printed Name

Thomas French

Authorized Signature

PWS Notification Date

PWS Person Notified

All units must be reported in
milligrams per liter (mg/L)

DWAR 04: Revised 07/2019

Submit completed form to:

EMAIL: WQD_Compliance_Data@azdeq.gov

-or-

MAIL: ADEQ Water Quality Compliance Data Unit (MC 5415B-1),

For questions go to:

azdeq.gov/DWComplianceAssistance

1110 W. Washington St., Phoenix, AZ 85007.